Send Quote Requests to info@automatedpt.com





DOP-110CS

High color • Wide screen • User-friendly Delta Electronics, Inc. No.18, Xinglong Rd., Taoyuan City 33068, Taiwan

Instruction Sheet

(1) General precautions

Thank you for purchasing this product. This instruction sheet provides information about the DOP-100 series HMI. Before using this product, please read through this instruction sheet carefully to ensure the correct use of the product. Please keep this sheet handy for quick reference whenever needed. Before finishing reading this sheet, please follow the instructions below:

- Install the product in an indoor location, which is free of vapor, corrosive and inflammable gas and
- Please refer to the wiring diagram when connecting the wires.
- Ensure your HMI is correctly grounded. The grounding method must comply with the national electrical standard (please refer to NFPA 70: National Electrical Code, 2005 Ed.).
- Do not disassemble the HMI or change the wiring when power is on.
- Do not touch the power supply when power is on, or it may cause electric shock.
- When the HMI displays a low power notification and requires a battery change, please contact your local distributor or Delta Customer Service Center for the replacement. Do not change the
- This product can be used with other industrial automation equipment. Please read through this sheet carefully and install the product according to the instructions to avoid danger.
- Cleaning method: please use a dry cloth to clean the product.
- This product must be used at an altitude below 2,000 m.
- If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.
- For repair and maintenance, please contact Delta Electronics, Inc. Address: No.18, Xinglong Rd., Taoyuan City, Taiwan. TEL: +886-3-3626301.

If you have any inquiry during operation, please contact our local distributors or Delta sales representatives. The content of this instruction sheet may be revised without prior notice. Please consult our distributors or download the latest version at Delta's website (http://www.delta.com.tw/ia).

(2) Communication port pin assignment

DOP-110CS COM1

COM Port	Pin	MODE1 RS-232
	1	-
	2	RXD
	3	TXD
a (1 5) a	4	-
	5	GND
6 6 9	6	-
	7	RTS
	8	CTS
	9	-


DOP-110CS COM2

	Pin	MODE1		MODE2		MODE3	
COM Port		COM2	СОМ3	COM2	COM3	COM2	COM3
		RS-232	RS-485	RS-485	RS-485	RS-232	RS-422
	1	-	-	D+	-	-	TXD+
	2	RXD	-	-	-	RXD	-
	3	TXD	-	-	-	TXD	-
5 1) 0	4	-	D+	-	D+	-	RXD+
	5	GND		GND		GND	
	6	-	-	D-	-	-	TXD-
	7	RTS	-	-	-	RTS	-
	8	CTS	-	-	-	CTS	-
	9	-	D-	-	D-	-	RXD-


Note: mark "-" means connection is not required.

(3) Description of each part

DOP-110CS (front view)




DOP-110CS (rear view)



Α	Power input terminal (24AWG wire min.)	В	COM2 / COM3
С	COM1	D	USB Host
E	USB Slave		

(4) Mounting dimensions

DOP-110CS



Operation temperature: 0°C to 50°C (32°F to 122°F) Storage temperature: -20°C to 60°C (-4°F to 140°F)

Call +1(800)985-6929 To Order or Order Online At Deltaacdrives.com


(5) Installation and wiring

Precautions:

- Incorrect installation may result in malfunction.
- To ensure the HMI is well ventilated, make sure there is sufficient space between the HMI and the adjacent objects or walls
- This product should be used on a case / platform which conforms to enclosure Type 4X standard (for indoor use only).
- The maximum panel thickness for mounting must be no greater than 5 mm.
- Copper conductor only.


Installation steps:

Put the waterproof gasket into the HMI and then insert the HMI into the panel cutout




Tighten the screws with the torque less than 0.5 N-M / 0.7 N-M to avoid damage to the plastic

Torque for DOP-110CS: 6.17 lb-inch (0.7 N-M)




Step 2:

Place the fasteners into the slots and tighten the screws until reaching the panel cutouts.



For heat dissipation, please keep a minimum clearance of 60 mm on the rear of the HMI.




Wiring:

=			
Туре	Wire gauge (AWG)	Stripped length	Torque
Solid	24 – 12	7 – 8 mm	5 kg-cm (4.3 lb-in)
Stranded	24 – 12	7 – 8 mm	5 kg-cm (4.3 lb-in)



Please refer to the following diagram when wiring the power connector. The temperature rating of the cable must be greater than 75°C (167°F).



Send Quote Requests to info@automatedpt.com

(6) Hardware specifications

Mo	del	DOP-110CS		
	Panel type	10.1" TFT LCD (65535 colors)		
	Resolution	1024 x 600 pixels		
Display	Backlight	LED Back Light (half-life under room temperature 25°C > 20,000 hours)*1		
	Display range	226 mm x 128.7 mm		
	Brightness	300 cd / m² (Typ.)		
CF	บ	ARM Cortex-A8 (800 MHz)		
Flash	ROM	256 Mbytes		
RA	M	256 Mbytes		
Touchs	screen	4-wire resistive touchscreen > 1,000,000 operated		
Buz	zer	Multi-tone Frequency (2K - 4K Hz) / 80dB		
Network interface		N/A		
US	SB	1 USB Slave Ver. 2.0; 1 USB Host Ver. 2.0		
S	D	N/A		
	COM1	RS-232 (supporting flow control)*2		
Serial communication	COM2	RS-232 (supporting flow control) / RS485*2		
port	COM3	RS-422 / RS-485 ^{*2}		
Auxiliary fu	ınction key	N/A		
Cale	ndar	Built-in		
Cooling	method	Natural cooling		
Appro	ovals	CE / UL (please use shielding network cable and magnetic ring with the filter of 300 ohm / 100 MHz)		
Panel water	rproof level	IP65 / NEMA4 / UL TYPE 4X (indoor use only)		
Operation	voltage*2	DC +24V (-15% to +15%) (please use an isolated power supply) Supplied by Class 2 or SELV circuit (isolated from MAINS by double insulation		
Leakage	current	500 V _{AC} for 1 minute (between DC24V terminal and FG terminal)		
Power con	sumption*2	10.4 W (Max)*3		
Backup	battery	3V lithium battery CR2032 × 1		
Backup battery life		About 3 years or more at 25°C (subject to operation temperature and condition)		
Operation temperature		0°C to 50°C (32°F to 122°F)		
Storage temperature		-20°C to +60°C (-4°F to 140°F)		
Operating environment		10% to 90% RH [0°C - 40°C], 10% to 55% RH [41°C - 50°C]; pollution degree: 2		
Vibration resistance		Conforms to IEC61131-2: continuous vibration 5 Hz - 8.3 Hz with amplitude 3.5 mm; 8.3 Hz - 150 Hz with amplitude 1G		
Shock resistance		Conforms to IEC60068-2-27: 11 ms, 15 G Peak, in X, Y, Z directions each for 6 times		
Dime (W) x (H)		272 x 200 x 61		
Mounting dimension (W) x (H) mm		261.3 x 189.3		
Weight		Approx. 1330 g		

Note:

- The half-life of the backlight is defined as the maximum luminance being reduced by 50% when the
 maximum drive current is supplied to the HMI. The life of LED backlight shown here is estimated at the
 room temperature of 25°C with ambient humidity.
- 2. The withstand voltage of the isolated power circuit is 1500V peak for 1 minute.
- The HMI power consumption is the power consumed when the HMI is not connecting with other peripheral devices. To ensure normal operation of the HMI, the recommended capacity of the power supply is 1.5 to 2 times of the specified power consumption.
- 4. Isolated power supply is recommended.
- 5. For the DOPSoft programming software of the DOP-100 series and the user manual, you can download them at http://www.delta.com.tw/ia.
- DOP-100 series can be used with other industrial automation equipment. Please read through this sheet carefully and install the product according to the instructions to avoid danger.

Call +1(800)985-6929 To Order or Order Online At Deltaacdrives.com

Send Quote Requests to info@automatedpt.com Call +1(800)985-6929 To Order or Order Online At Deltaacdrives.com